

PUBLIC HEALTH ENGINEERING DEPARTMENT
DISTRICT WATER TESTING LABORATORY, PANCHKULA

Website :- <https://phedharyana.gov.in/>

Contact No. - 87 D.

Memo No:- 308

Date:- 26/03/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : PKL/08922/3/2025 / Private	Sample Details	Date & Time
Sender : Parvinder Singh	Collected By	Parvinder Singh
Location : , Vishva Shiksha Niketan Sr.Sec.School,Virat Nagar	Collection Date	24/03/2025 at 11:30
Sample Description : Drinking Water	Received at lab	24/03/2025 at 11:38
Latitude / Longitude : 76.921122 / 30.771520	Analysis Start Date	25/03/2025
	Analysis End Date	26/03/2025
	Sample Quantity	2 ltr

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<2.00	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-S) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	<5.00	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-C
5	Total Dissolved Solids @ 180°C ± 2°C	392.0	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	154.0	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	57.8	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	<5.00	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	124.0	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	19.2	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	22.59	200 mg/lit.	400 mg/lit.	USEPA
12	Fluoride as F	0.18	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition 4500 F-C
13	Iron as Fe	0.14	1.0 mg/lit.	1.0 mg/lit.	IS 3025:(PART53):2024
14	Nitrate as No3	7.10	45 mg/lit.	45 mg/lit.	APHA 4500-NO3- B
15	pH @ 25°C	7.43	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED PANCHKULA Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

Sonia Badesara
SONIA BADESARA, CHEMIST
DISTRICT WATER TESTING LABORATORY PANCHKULA
email:-chemist.panchkula@phedharyana.gov.in